

| Location Information | | | System-Owned Portion | | | | | | | | | | Customer-Owned Portion | | | | | | | Entire Service Line Material Classification (if error or Missing Information appears, ensure all required columns are filled correctly. See instructions). |
|------------------------|--|-----------------------------|---|--------------------------|--|--------------------------------|----------------------------|----------------------------------|---|--|--------------------------------------|---|---|--------------------------------|----------------------------|----------------------------------|---|--|--------------------------------------|--|
| Unique Service Line ID | Street Address | Other Locational Identifier | System-Owned Portion Service Line Material Classification | Lead Connect or Present? | If Material Anything Other than "Lead" in Column E, Was Material Ever Previously Lead? | Service Line Installation Date | Service Line Size (inches) | Basis of Material Classification | Was the Service Line Material Field Verified? | Describe the Field Verification Method | Enter the Date of Field Verification | Notes | Customer-Owned Portion Service Line Material Classification | Service Line Installation Date | Service Line Size (inches) | Basis of Material Classification | Was the Service Line Material Field Verified? | Describe the Field Verification Method | Enter the Date of Field Verification | |
| 008-070-005 | 10200 FIDDLETOWN ROAD | water tank/ cell tower | Non-Lead - Plastic | No | No | 1996 | 1.50 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | New development verified by spec plans. | Non-Lead - Other | 1996 | 1.50 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 008-070-029 | 10010 SHENANDOAH ROAD | | | | Don't know | | 1.50 | | | | | | | | 1.50 | | | | | Missing Information |
| 010-150-026 | 9701 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-150-027 | 9659 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-063-006 | 18726 HIGHWAY 49 | | Non-Lead - Plastic | No | Don't know | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-063-003 | 18720 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-178-001 | 18806 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-178-002 | 18818 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-178-003 | 18832 HIGHWAY 49 | | Non-Lead - Plastic | No | Don't know | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-178-004 | 18846 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 008-040-003 | 18930 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 008-040-002 | 18960 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 008-040-001 | 18990 HIGHWAY 49 | | Non-Lead - Plastic | No | No | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | HERD TROUGH | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-032-013 | 9569 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-032-012 | 9565 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-032-011 | 9559 MAIN STREET | | | | Don't know | 2000 | 0.75 | | | | | | | 2000 | 0.75 | | | | | Missing Information |
| 010-032-010 | 9549 MAIN STREET | | Non-Lead - Plastic | No | Don't know | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-062-001 | 18725 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-032-009 | MAIN STREET ROUNDABOUT 9525 MAIN STREET | center island landscape | | | No | | 1.00 | | | | | | | | 1.00 | | | | | Missing Information |
| | | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | | |
|-------------|---------------------|-----------------------|--------------------|----|------------|---------|------|--|-----|------------------------------------|-----------|--|--------------------|------|------------------|--|------------------------------------|------------------------------------|---------------------|----------|
| 010-032-008 | 9511 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead | |
| 010-031-023 | 9477 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information | |
| 010-032-016 | 9449 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information | |
| 010-180-044 | 9470 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-043 | 9476 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-042 | 9480 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-041 | 9486 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-040 | 9490 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-039 | 9496 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-038 | 9500 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-037 | 9506 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-036 | 9510 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-035 | 9516 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-034 | 9520 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-033 | 9526 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-050 | 9521 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-049 | 9491 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-048 | 9485 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-047 | 9481 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |
| 010-180-046 | 9475 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 1988 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead | |

| | | | | | | | | | | | | | | | | | | | | |
|-------------|--------------------|-----------------------|--------------------|----|----|-----------|------|------------------|-----|------------------------------------|-----------|--|--------------------|-----------|------|------------------|-----|------------------------------------|-----------|---------------------|
| 010-180-045 | 9471 VICTORIAN WAY | Victorian Development | Non-Lead - Plastic | No | No | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1988 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-023 | 18884 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-022 | 18892 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-021 | 18896 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-024 | 18891 WHEELER WAY | | Non-Lead - Plastic | No | No | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Galvanized | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-025 | 18897 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-020 | 18900 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-019 | 18904 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-026 | 18903 WHEELER WAY | | Non-Lead - Plastic | No | No | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-027 | 18907 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-018 | 18908 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-017 | 18912 WHEELER WAY | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-016 | 18916 WHEELER WAY | | Non-Lead - Plastic | No | No | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-015 | 9456 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-014 | 9452 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-013 | 9448 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-012 | 9444 WHEELER LOOP | | Non-Lead - Plastic | No | No | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-011 | 9440 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-010 | 9436 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-009 | 9432 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-028 | 9449 WHEELER LOOP | | Non-Lead - Plastic | No | No | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-029 | 9431 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-030 | 9427 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-031 | 9409 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-008 | 9428 WHEELER LOOP | | Non-Lead - Plastic | No | No | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-007 | 9424 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-006 | 9420 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-005 | 9416 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |
| 010-180-004 | 9412 WHEELER LOOP | | Non-Lead - Plastic | No | No | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1985/1986 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-180-003 | 9408 WHEELER LOOP | | | | No | 1985/1986 | 0.75 | | | | | | | 1985/1986 | 0.75 | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | |
|----------------|-------------------------|-----------------------|--------------------|----|------------|---------|------|----------------------------------|-----|------------------------------------|------------|--|--------------------|------|------------------|--|------------------------------------|------------|---------------------|
| 010-178-005-24 | 9419 LANDRUM STREET #24 | Plymouth Mobile Manor | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-178-005-23 | 9419 LANDRUM STREET #23 | Plymouth Mobile Manor | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-178-005-22 | 9419 LANDRUM STREET #22 | Plymouth Mobile Manor | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-178-005-21 | 9419 LANDRUM STREET #21 | Plymouth Mobile Manor | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-178-005-20 | 9419 LANDRUM STREET #20 | Plymouth Mobile Manor | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-178-005-19 | 9419 LANDRUM STREET #19 | Plymouth Mobile Manor | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-031-014 | 9431 MAIN STREET | McGee Park | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-002 | 9395 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | 2003 | 0.75 | Field inspection | No | | | | Non-Lead - Plastic | 2003 | 0.75 | Field inspection | No | | Non-lead |
| 010-021-017 | 9383 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Copper | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-021-023-01 | 9375 LANDRUM STREET #1 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-023-02 | 9375 LANDRUM STREET #2 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-006 | 9369 LANDRUM STREET | | Non-Lead - Plastic | No | No | 2004 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 2004 | 0.75 | Installation date is after state or local lead ban | No | | Non-lead |
| 010-023-005 | 9363 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-023-006 | 9369 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-016-01 | 9363 LANDRUM STREET #1 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-016-02 | 9363 LANDRUM STREET #2 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-021-016-03 | 9363 LANDRUM STREET #3 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-021-016-04 | 9363 LANDRUM STREET #4 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-008 | 9353 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-019 | 9343 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-010 | 9331 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-021-025 | 9315 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-021-011 | 18765 CHURCH STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-022-002 | 9325 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-023-011 | 9328 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | Non-lead |
| 010-023-013 | 9337 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-023-013 | 9333 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-022-004 | 9313 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | | | |
|----------------|--------------------------|--|--------------------|----|------------|---------|------|----------------------------------|-----|------------------------------------|------------|--|--------------------|------|------|--|-----|------------------------------------|------------|--|---------------------|
| 010-051-007 | 9314 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-lead |
| 010-051-006 | 9300 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-051-013 | 9282 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-051-004 | 9268 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-051-003 | 9256 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-051-002 | 9244 MAIN STREET | | Non-Lead - Plastic | No | Don't know | 1987 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | 1987 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-lead |
| 010-051-001 | 9200 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-014 | 9205 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-040-004 | 9196 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/20/2024 | | Non-lead |
| 010-012-016 | 9187 MAIN STREET | | Non-Lead - Plastic | No | No | 2001 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 2001 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-040-003 | 9184 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-005 | 9169 MAIN STREET | | Non-Lead - Plastic | No | Don't know | 2006 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/15/2024 | | Non-Lead - Plastic | 2006 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 8/15/2024 | | Non-lead |
| 010-012-020 | 9155 MAIN STREET | | Non-Lead - Plastic | No | Don't know | 1999 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | 1999 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-012-019 | 9141 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-003 | 9117 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-001 | 9087 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-002 | 9069 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-lead |
| 010-011-048 | 9055 MAIN STREET | | Non-Lead - Plastic | No | No | 2000 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 2000 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-011-048 | 9055 A MAIN STREET | | Non-Lead - Plastic | No | No | 2000 | 0.75 | Installation date after lead ban | No | | | | Non-Lead - Plastic | 2000 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 008-060-042 | 9005 OLD SACRAMENTO ROAD | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-040-006-08 | 999999 MAIN STREET #8 | | Non-Lead - Plastic | No | Don't know | | 2.00 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Copper | | 2.00 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-lead |
| 010-040-005-07 | 999999 MAIN STREET #7 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-040-002 | 9130 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-040-001-01 | 999999 MAIN STREET #1 | | | | Don't know | | 2.00 | | | | | | | | 2.00 | | | | | | Missing Information |
| 010-012-009 | 9227 MAIN STREET | | Non-Lead - Plastic | No | Don't know | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-lead |
| 010-012-010 | 9239 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-011 | 9255 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-012 | 9275 MAIN STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | | |
|-------------|---------------------|--|--------------------|----|------------|---------|------|--|-----|------------------------------------|----------|------------------|--------------------|------|--|--|-----|------------------------------------|----------|---------------------|
| 010-012-005 | 9170 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | 2005 | 0.75 | Installation date after lead ban | No | | | Non-Lead - Other | 2005 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-011-012 | 9081 LANDRUM STREET | | | | Don't know | | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-003 | 9101 LANDRUM STREET | | | | Don't know | | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-002 | 9100 LANDRUM STREET | | | | Don't know | | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-051 | 9123 LANDRUM STREET | | | No | Don't know | | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-052 | 9135 LANDRUM STREET | | | | Don't know | | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-011-028 | 9149 LANDRUM STREET | | | | Don't know | | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-011-006 | 9163 LANDRUM STREET | | | | Don't know | | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-049 | 9187 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | 1992 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Plastic | 1992 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | Non-lead |
| 010-011-050 | 9175 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-015 | 9182 LANDRUM STREET | | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-011-050 | 9183 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-044 | 9191 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | Non-lead |
| 010-011-020 | 9215 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-030 | 9207 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-037 | 9217 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-038 | 9219 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | Non-lead |
| 010-011-039 | 9221 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-040 | 9223 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-012-013 | 9224 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-035 | 9225 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Other | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | Non-lead |
| 010-011-024 | 9237 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-025 | 9251 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-011-008 | 9265 LANDRUM STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-021-013 | 9285 LANDRUM STREET | | Non-Lead - Plastic | No | Don't know | 1995 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Plastic | 1995 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | Non-lead |
| 010-021-024 | 9295 LANDRUM STREET | | Non-Lead - Plastic | No | No | 2005 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2005 | 0.75 | Installation date is after state or local lead ban | No | | | Non-lead |
| 010-053-003 | 9356 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-023-004 | 9359 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-023-007 | 9379 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | Non-lead |

| | | | | | | | | | | | | | | | | | | | | | |
|-------------|----------------------|-----------|--------------------|----|------------|---------|------|------------------|-----|------------------------------------|------------|------|----------------------------------|------|------|------------------|-----|------------------------------------|------------|--|----------------------------------|
| 010-023-008 | 9383 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-023-009 | 9393 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-061-001 | 9414 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-005 | 9426 MAIN STREET | City Hall | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | IRON | Non-Lead - Copper | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/3/2024 | | Non-lead |
| 010-061-007 | 9446 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-008 | 9454 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-031-012 | 9451 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-024 | 9486 MAIN STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Non-lead |
| 010-062-002 | 9506 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-017 | 9470 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-023 | 18685 MILL STREET | | | | Don't know | Unknown | 0.63 | | | | | | | | 0.63 | | | | | | Missing Information |
| 010-092-004 | 18635 HIGHWAY 49 | | Non-Lead - Plastic | No | Don't know | Unknown | 1.00 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Non-Lead - Plastic | | 1.00 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Non-lead |
| 010-061-018 | 18651 MILL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-020 | 18635 MILL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-016 | 18621 MILL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-021 | 18620 MINERAL STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Galvanized Requiring Replacement | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Galvanized Requiring Replacement |
| 010-061-019 | 18600 MINERAL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-019 | 18602 MINERAL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-026 | 18665 MILL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-061-025 | 18610 MINERAL STREET | | Non-Lead - Plastic | No | No | 1990 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Non-Lead - Plastic | 1990 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 9/18/2024 | | Non-lead |
| 010-061-022 | 18654 MINERAL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-005 | 9402 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-004 | 9398 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-016 | 18661 MINERAL STREET | | Non-Lead - Other | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-054-008 | 18649 MINERAL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-009 | 18637 MINERAL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-010 | 18625 MINERAL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |
| 010-091-017 | 18605 MINERAL STREET | | Non-Lead - Plastic | No | Don't know | 2003 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Galvanized Requiring Replacement | 2003 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Galvanized Requiring Replacement |
| 010-091-013 | 18603 MINERAL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | | |
|----------------|------------------------|--|--------------------|----|------------|---------|------|--|-----|------------------------------------|------------|-------|--------------------|------|------|--|-----|------------------------------------|------------|---------------------|
| 010-091-016 | 18571 MILL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-091-016 | 18581 MILL STREET | | Non-Lead - Plastic | No | No | 2005 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2005 | 0.75 | Installation date is after state or local lead ban | No | | | Non-lead |
| 010-091-003 | 18561 MILL STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-091-009 | 18550 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-091-010 | 18523 MILL STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-093-002 | 18624 HIGHWAY 49 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-093-002-01 | 18620 HIGHWAY 49 #1 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-093-002-02 | 18620 HIGHWAY 49 #2 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-093-003-04 | 18594 HIGHWAY 49 #4 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-093-003-03 | 18594 HIGHWAY 49 #3 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-093-003-02 | 18594 HIGHWAY 49 #2 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-093-003-01 | 18594 HIGHWAY 49 #1 | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-093-004 | 18568 HIGHWAY 49 | | | | Don't know | | 1.00 | | | | | | | | 1.00 | | | | | Missing Information |
| 010-093-006 | 9493 LAVERONE STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-093-007 | 9505 LAVERONE STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-093-009 | 9525 LAVERONE STREET | | Non-Lead - Plastic | No | Don't know | 1993 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | 1993 | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-120-003 | 9535 LAVERONE STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-120-006 | 9464 QUARTZ STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-120-005 | 9474 QUARTZ STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-120-007 | 9490 PACIFIC STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-120-007 | 9450 PACIFIC STREET | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-111-002 | 18410 HIGHWAY 49 | | | | Don't know | | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-111-003 | 9451 PACIFIC STREET | | Non-Lead - Plastic | No | Don't know | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | BRASS | Unknown | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Lead Status Unknown |
| 010-150-016 | 9424 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-150-016-01 | 9424 PACIFIC STREET #1 | | | | Don't know | Unknown | 1.50 | | | | | | | | 1.50 | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | | |
|----------------|-----------------------|--------------------|----|------------|------------|---------|--|-----|------------------------------------|------------|--|----------------------------------|------|------|--|-----|------------------------------------|------------|--|----------------------------------|
| 010-132-010 | 9408 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-132-002 | 9394 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-111-004 | 9381 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-131-012 | 9358 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.63 | | | | | Missing Information |
| 010-132-001 | 18280 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-132-008 | 18260 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-131-004 | 18261 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-131-005 | 18251 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-132-007 | 18230 SUTTER STREET | Non-Lead - Plastic | No | No | 1988 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Other | 1988 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-131-009 | 9351 ATLANTIC STREET | Non-Lead - Plastic | No | No | 2003 | 0.75 | Installation date is after state or local lead ban | | | | | Non-Lead - Plastic | 2003 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-142-012 | 9350 ATLANTIC STREET | Non-Lead - Plastic | No | No | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-131-008 | 9335 ATLANTIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-142-011 | 9340 ATLANTIC STREET | Non-Lead - Plastic | No | No | 2019 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2019 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-142-010 | 9330 ATLANTIC STREET | Non-Lead - Plastic | No | No | 1994 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1994 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-200-009 | 17590 HIGHWAY 49 | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-200-008 | 17594 HIGHWAY 49 | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-200-004 | 17674 E VILLAGE DRIVE | Non-Lead - Plastic | No | Don't know | Unknown | 2.00 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Galvanized Requiring Replacement | | 2.00 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Galvanized Requiring Replacement |
| 010-200-005 | 17699 E VILLAGE DRIVE | | | | Don't know | Unknown | 1.00 | | | | | | | | 1.00 | | | | | Missing Information |
| 010-200-002 | 17810 HIGHWAY 49 | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-200-001 | 17830 HIGHWAY 49 | | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-160-002 | 17870 HIGHWAY 49 | Non-Lead - Plastic | No | Don't know | Unknown | 1.00 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 1.00 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-160-013 | 18170 HIGHWAY 49 | Non-Lead - Plastic | No | Don't know | Unknown | 2.00 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 2.00 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-160-010-02 | 9252 BUSH STREET #2 | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-160-010-01 | 9252 BUSH STREET #1 | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-160-010-03 | 9252 BUSH STREET #3 | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |
| 010-160-010-04 | 9252 BUSH STREET #4 | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-lead |

| | | | | | | | | | | | | | | | | | | | |
|----------------|------------------------|--|--------------------|------------|------------|---------|------|--|-----|------------------------------------|------------|--|--------------------|------|---|----------------------------------|------------------------------------|------------|---------------------|
| 010-131-007 | 18264 EMPIRE STREET | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-131-010 | 18242 EMPIRE STREET | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-142-005 | 18188 EMPIRE STREET | | | Don't know | Unknown | 0.75 | | | | | | | | 0.75 | | | | | Missing Information |
| 010-141-008 | 9280 BUSH STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-141-007 | 9264 BUSH STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-141-009 | 18129 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-144-001-01 | 18090 EMPIRE STREET #1 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-144-001 | 18090 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-142-004 | 18164 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-142-008 | 9327 BUSH STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-144-003 | 9350 BUSH STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-142-006 | 9351 BUSH STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-144-010 | 18122 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-144-008 | 18110 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-144-008-01 | 18110 SUTTER STREET #1 | | | | Don't know | Unknown | 1.00 | | | | | | | 1.00 | | | | | Missing Information |
| 010-144-005 | 9408 BUSH STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-143-002 | 9437 BUSH STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-143-003 | 9417 BUSH STREET | | Non-Lead - Plastic | No | Don't know | Unknown | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | | Non-Lead - Plastic | 0.75 | Field inspection | Yes | Visual inspection at the meter pit | 10/15/2024 | Non-lead |
| 010-144-011 | 9390 BUSH STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-143-005 | 18156 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-142-007 | 18181 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-142-013 | 18191 SUTTER STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-111-009 | 9351 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-131-011 | 9350 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-111-005 | 9335 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-131-002 | 9336 PACIFIC STREET | | Non-Lead - Plastic | No | Don't know | 2012 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2012 | 0.75 | Installation date after lead ban | No | | Non-lead |
| 010-131-001 | 9318 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-131-001 | 9310 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-111-008 | 9313 PACIFIC STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-111-006 | 18328 HIGHWAY 49 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |
| 010-070-003 | 18265 HIGHWAY 49 | | Non-Lead - Other | No | Don't know | Unknown | 6.00 | Service line diameter 4 inches or greater | No | | | | Non-Lead - Other | 6.00 | Service line diameter 4 inches or greater | No | | | Non-lead |
| 010-101-011 | NO ADDRESS ASSIGNED | | | | Don't know | Unknown | 2.00 | | | | | | | 2.00 | | | | | Missing Information |
| 010-102-006 | 18340 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | | | |
|----------------|------------------------|--------------------|----|----|------------|---------|--|--|----|--|--------------------|------|------|--|----|--|--|--|--|---------------------|---------------------|
| 010-101-009 | 18379 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.63 | | | | | | Missing Information | |
| 010-102-007 | 18380 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-102-008 | 18390 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-101-022 | 18391 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-101-021 | 18401 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-101-007 | 18411 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.63 | | | | | | Missing Information | |
| 010-102-001 | 18430 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-101-005 | 18431 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-082-004 | 18467 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-030 | 18464 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-029-01 | 18490 EMPIRE STREET #1 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-029-02 | 18490 EMPIRE STREET #2 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-082-010 | 18481 EMPIRE STREET | Non-Lead - Plastic | No | No | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | Non-Lead - Plastic | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | | | Non-lead | |
| 010-082-010 | 18485 EMPIRE STREET | Non-Lead - Plastic | No | No | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | Non-Lead - Plastic | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | | | | Non-lead |
| 010-082-003 | 18511 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-026 | 18510 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-082-002 | 18529 EMPIRE STREET | | | | Don't know | 2002 | 0.75 | Installation date is after state or local lead ban | No | | Non-Lead - Plastic | 2002 | 0.75 | Installation date is after state or local lead ban | No | | | | | | Missing Information |
| 010-083-016 | 18520 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-020 | 18572 FADDIS ALLEY | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-023 | 18554 FADDIS ALLEY | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-018 | 18544 FADDIS ALLEY | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-024 | 18538 FADDIS ALLEY | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-017 | 18532 FADDIS ALLEY | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-083-021 | 18550 EMPIRE STREET | | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information | |
| 010-083-022 | 18570 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-082-001 | 18565 N EMPIRE STREET | | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information | |
| 010-083-001 | 18596 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-053-009 | 18614 EMPIRE STREET | | | | Don't know | Unknown | 1.00 | | | | | | | 1.00 | | | | | | Missing Information | |
| 010-052-006 | 9302 HAY STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-053-011 | 18650 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-051-008 | 18651 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-052-005 | 9280 HAY STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-051-009-01 | 9269 HAY STREET #1 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-051-009-02 | 9269 HAY STREET #2 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |
| 010-051-009-03 | 9269 HAY STREET #3 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information | |

| | | | | | | | | | | | | | | | | | | | | |
|----------------|--------------------------|--------------|--------------------|----|------------|---------|------|--|----|--|--|--------------------|------|------|--|----|--|--|--|---------------------|
| 010-051-009-04 | 9269 HAY STREET #4 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-051-009-05 | 9269 HAY STREET #5 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-052-003 | 9254 HAY STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-052-002 | 9236 HAY STREET | | Non-Lead - Plastic | No | No | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | Non-Lead - Plastic | 2004 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-lead |
| 010-051-010 | 9251 HAY STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-051-011 | 9241 HAY STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-052-001 | 18600 SHERWOOD STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-052-001-01 | 18600 SHERWOOD STREET #1 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-040-005 | 18601 SHERWOOD STREET | | | | Don't know | Unknown | 2.00 | | | | | | | 2.00 | | | | | | Missing Information |
| 010-082-008-01 | 18565 N EMPIRE STREET #1 | Lodge Hill | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-070-001 | 18551 SHERWOOD STREET | City Pool | | | Don't know | Unknown | 2.00 | | | | | | | 2.00 | | | | | | Missing Information |
| 010-070-001-01 | 18551 SHERWOOD STREET #1 | City Pool | | | Don't know | Unknown | 1.50 | | | | | | | 1.50 | | | | | | Missing Information |
| 010-082-008 | 18534 SHERWOOD STREET | Fire Station | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-082-008 | 18534 SHERWOOD STREET | Ambulance | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-082-007 | 18500 SHERWOOD STREET | Corp Yard | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-081-004 | 18481 SHERWOOD STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-081-006 | 18463 SHERWOOD STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-070-001 | 18621 SHERWOOD STREET | | Non-Lead - Other | No | No | Unknown | 4.00 | Service line diameter 4 inches or greater | No | | | Non-Lead - Other | | 4.00 | Service line diameter 4 inches or greater | No | | | | Non-lead |
| 010-070-001 | 18621 SHERWOOD STREET | | Non-Lead - Other | No | No | Unknown | 6.00 | Service line diameter 4 inches or greater | No | | | Non-Lead - Other | | 6.00 | Service line diameter 4 inches or greater | No | | | | Non-lead |
| 010-101-013 | 9204 LOCUST STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-101-015 | 18435 GERRANS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-101-014 | 18417 GERRANS STREET | | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-101-016 | 18389 GERRANS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-101-017 | 18390 GERRANS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-101-018 | 18402 GERRANS STREET | | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-101-003 | 18418 GERRANS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-101-004 | 9250 LOCUST STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-082-009 | 9235 LOCUST STREET | | | | No | 2006 | 0.75 | Installation date is after state or local lead ban | | | | | 2006 | 0.75 | | | | | | Missing Information |
| 010-101-006 | 18421 EMPIRE STREET | | | | Don't know | Unknown | 1.00 | | | | | | | 1.00 | | | | | | Missing Information |
| 010-082-005 | 9279 LOCUST STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-083-013 | 18452 EMPIRE STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-083-012 | 9337 LOCUST STREET | | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-083-011 | 9351 LOCUST STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-102-002 | 9350 LOCUST STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |

| | | | | | | | | | | | | | | | | | | | | |
|----------------|-----------------------|-----------------------|--------------------|----|------------|-----------|------|--|----|--|--|--|--------------------|-----------|------|--|----|--|--|---------------------|
| 010-102-004 | LOCUST STREET | | | | Don't know | Unknown | 2.00 | | | | | | | 2.00 | | | | | | Missing Information |
| 010-083-010 | 9381 LOCUST STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-084-003-01 | 18470 DAVIS STREET #1 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-084-003-02 | 18470 DAVIS STREET #2 | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-084-005 | 18503 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-084-005 | 18519 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-084-004 | 18494 DAVIS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-083-009 | 18483 DAVIS STREET | | Non-Lead - Plastic | No | No | 2005 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2005 | 0.75 | Installation date is after state or local lead ban | No | | | Non-lead |
| 010-083-027 | 18505 DAVIS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-083-028 | 18519 DAVIS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-083-005 | 18531 DAVIS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-083-004 | 18545 DAVIS STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-091-005 | 18534 POPLAR STREET | | | | Don't know | Unknown | 0.63 | | | | | | | 0.63 | | | | | | Missing Information |
| 010-091-012 | 18554 POPLAR STREET | | Non-Lead - Plastic | No | No | 1990 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1990 | 0.75 | Installation date is after state or local lead ban | No | | | Non-lead |
| 010-083-002 | 18575 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-091-011 | 18574 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-091-007 | 18594 POPLAR STREET | | Non-Lead - Plastic | No | No | 2001 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2001 | 0.75 | Installation date is after state or local lead ban | No | | | Non-lead |
| 010-054-011 | 18624 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-053-005 | 18631 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-053-004 | 18655 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-018 | 18640 POPLAR STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-017 | 18650 POPLAR STREET | | Non-Lead - Plastic | No | No | 1991 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1991 | 0.75 | Installation date is after state or local lead ban | No | | | Non-lead |
| 010-054-001 | 9372 MAIN STREET | | | | Don't know | Unknown | 1.50 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-054-003 | 9392 MAIN STREET | | | | Don't know | Unknown | 0.75 | | | | | | | 0.75 | | | | | | Missing Information |
| 010-174-008 | 18961 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | Non-lead |
| 010-172-017 | 18960 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | Non-lead |
| 010-174-007 | 18981 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 2002 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 2002 | 0.75 | Installation date after lead ban | No | | | Non-lead |
| 010-174-006 | 19001 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | Non-lead |
| 010-172-016 | 18990 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | Non-lead |

| | | | | | | | | | | | | | | | | | | | | | |
|-----------------|-------------------|-----------------------------|--------------------|----|----|-----------|------|--|----|--|--|---|--------------------|-----------|------|----------------------------------|----|--|--|--|----------|
| 010-176-013 | 18901 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | | Non-lead |
| 010-177-022 | 18910 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | | Non-lead |
| 010-177-023 | 18930 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | | Non-lead |
| 010-176-012 | 18921 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992 | 0.75 | Installation date after lead ban | No | | | | Non-lead |
| 010-176-011 | 18931 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992 | 0.63 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992 | 0.75 | Installation date after lead ban | No | | | | Non-lead |
| 010-177-024 | 18940 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | | Non-lead |
| 010-176-010 | 18941 GOLDEN WAY | Hawksview Development | Non-Lead - Plastic | No | No | 1992-2024 | 0.75 | Installation date is after state or local lead ban | No | | | | Non-Lead - Plastic | 1992-2024 | 0.75 | Installation date after lead ban | No | | | | Non-lead |
| Landscape Water | ZINFANDEL PARKWAY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 2.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 2.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-002 | 8888 PORT DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-001 | 8878 PORT DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-003 | 8868 PORT DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-004 | 8846 PORT DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-005 | 8822 PORT DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-006 | 8802 PORT DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-007 | 8796 PORT DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |

| | | | | | | | | | | | | | | | | | | | | | |
|-------------|----------------------|-----------------------------|--------------------|----|----|---------|------|--|----|--|--|---|--------------------|---------|------|----------------------------------|----|--|--|--|----------|
| 008-460-025 | 17932 VINTNER COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-026 | 17916 VINTNER COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-008 | 8609 VINTNER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-009 | 17929 RIESLING COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-010 | 17935 RIESLING COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-011 | 17941 RIESLING COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-012 | 17950 RIESLING COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-013 | 8643 VINTNER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-014 | 8659 VINTNER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-015 | 8699 VINTNER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-024 | 8748 VINTNER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-002 | 8724 VINTNER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |

| | | | | | | | | | | | | | | | | | | | | | |
|-------------|------------------------|-----------------------------|--------------------|----|----|---------|------|--|----|--|--|---|--------------------|---------|------|----------------------------------|----|--|--|--|----------|
| 008-470-022 | 8784 ZINFANDEL PARKWAY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-470-023 | 8764 ZINFANDEL PARKWAY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-002 | 8821 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-001 | 8828 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-014 | 8852 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-013 | 18009 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-012 | 18073 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-011 | 18097 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-010 | 18105 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-022 | 18110 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-021 | 18104 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-020 | 18096 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |

| | | | | | | | | | | | | | | | | | | | | | |
|-------------|----------------------|-----------------------------|--------------------|----|----|---------|------|--|----|--|--|---|--------------------|---------|------|----------------------------------|----|--|--|--|----------|
| 008-480-006 | 18050 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-005 | 18044 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-019 | 18028 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-480-018 | 18024 HARVEST COURT | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-007 | 8732 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-008 | 8690 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-018 | 8672 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-010 | 8636 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-011 | 8596 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-012 | 8574 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-013 | 8550 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-014 | 8535 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |

| | | | | | | | | | | | | | | | | | | | | | |
|-------------|----------------------|-----------------------------|--------------------|----|----|---------|------|--|-----|------------------------------------|-----------|---|--------------------|---------|------|---------------------------------------|-----|------------------------------------|-----------|--|----------|
| 008-490-015 | 8567 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-016 | 8591 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-017 | 8605 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-018 | 8631 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-019 | 8665 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-020 | 8687 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | Yes | Visual inspection at the meter pit | 8/29/2024 | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Field inspection only with no records | Yes | Visual inspection at the meter pit | 8/29/2024 | | Non-lead |
| 008-490-021 | 8689 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-022 | 8701 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-024 | 8711 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-023 | 8733 SOMMELIER DRIVE | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-006 | 8689 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-005 | 8659 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |

| | | | | | | | | | | | | | | | | | | | | | |
|-------------|---------------------|-----------------------------|--------------------|----|----|---------|------|--|----|--|--|---|--------------------|---------|------|----------------------------------|----|--|--|--|----------|
| 008-490-004 | 8633 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-003 | 8595 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-002 | 8567 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-490-001 | 8543 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-033 | 8544 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-032 | 8570 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-031 | 8590 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-030 | 8608 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-029 | 8626 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-028 | 8642 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |
| 008-460-027 | 8662 ZINFANDEL PKWY | Zinfandel Ridge Development | Non-Lead - Plastic | No | No | 2016-23 | 1.00 | Installation date is after state or local lead ban | No | | | New development verified by spec plans. | Non-Lead - Plastic | 2016-23 | 1.00 | Installation date after lead ban | No | | | | Non-lead |